

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department
Annual Periodical Renewal Fire Certificate

From
The District Fire Officer
Andhra Pradesh Visakhapatnam

To
District Educational Officer
Visakhapatnam

FileNo.13372/VSP/DFO/2020,Date:06/08/2020
Occupancy NoC Rc.Number:8753/VSP/DFO/2019

Sub: Andhra Pradesh State Disaster Response and Fire Services Department – Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of Sanghamitra Educational Society (Harbor EM High School), represented by M/s Sanghamitra Educational Society, Sy.No.278/1, Vellanki, Peddipalem (V), Anandapuram (M) - Regarding.

- Ref: 1. G.O.Ms.No.71 Home (Prisons-A) Department , Dated.01-04-2010 & G.O.Ms.NO.140 Home (Prison & Fire Services) Department, Dt:04-09-2015.
2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
3. This Office NOC for Occupancy Rc.No.8753/VSP/DFO/2019,Dt:23/07/2019
4.Renewal NOC for Occupancy 8753/VSP/DFO/2019, Dt.23/09/2019
5. Online Application for Renewal NOC of M/s Sanghamitra Educational Society, Sy.No.278/1, Vellanki, Peddipalem (V), Anandapuram (M)- Inspection report called for Regarding.
6. Online Inspection Report submitted by Officers of this Department on 06-08-2020.

<< 0 >>

The management of Sanghamitra Educational Society (Harbor EM High School), represented by M/s Sanghamitra Educational Society, Sy.No.278/1, Vellanki, Peddipalem (V), Anandapuram (M) has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.139896/- vide challan No.41055469122020, Dated 29/06/2020 at State Bank of India, Visakhapatnam.

Sanghamitra Educational Society (Harbor EM High School)

1. This Certificate is being issued as per G.O.Ms.No.140 Home (Prisons & Fire Services) Department, DtL04.09.2015
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate M/s Sanghamitra Educational Society, Sy.No.278/1, Vellanki, Peddipalem (V), Anandapuram (M), subject to the following conditions.

SI	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

Jhannu Nandan
Secretary & Correspondent

HEAD MASTER
HARBOR E.M. SCHOOL
VELLANKI, BODDAPALEM (V), VELLANKI, BODDAPALEM
Anandapuram (Md), VSP Dt. Anandapuram (Md), VSP Dt.

2	Any loss of life or property due to non- functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This No objection Certificate for occupancy is valid for one year from the date of issue of this letter	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once from nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 23/07/2020 to 22/07/2025.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management

Basing on the Inspection Committee Report : 1) The management has obtained NoC for occupancy vide Rc.No.8753/DFO/VSP/2019, Dt:23.07.2019. 2) The management has paid the 5 years renewal fee of Rs.140700/- (Vide Challan No.41079063332020, of Rs.15,140/- Dated:15.07.2020 & 41055469122020, of Rs.13,000/- dated:29.06.2020 Rs.112560/- vide challan no.41100823192020, dt.0.6.08.2020 and uploaded) total built -up area of 5627.87 Sq.Mtrs.,.

Your Sincerely,

[Signature]
 District Fire Officer
 Andhra Pradesh, Visakhapatnam
 Visakhapatnam

- Copy to Management Sanghamitra Educational Society (Harbor EM High School), Sy.No.278/1, Vellanki, Peddipalem (V), Anandapuram (M)
 Copy to Assistant District Fire Officer concerned
 Copy to Station Fire Officer concerned



SANGAMITRA EDUCATIONAL SOCIETY
[Signature]
 Secretary & Correspondent

[Signature]
 HEAD MASTER
 HARBOR E.M. SCHOOL
 VELLANKI, BODDAPALEM (V)
 Anandapuram (Md), VSP Dt.

SANGAMITRA EDUCATIONAL SOCIETY

Regd. 56/1988

PRESIDENT

ALLU BHANUMATHI, M.A., M.Ed.,

Ex. MLA

Cell : 9490459019

SECRETARY

Y. SANYASI NAIDU, B.Sc., B.L

Cell : 9440156652

TREASURER

Y. RAGHU RAJ, M.B.A

Cell : 9493887644

The District Fire Officer,
Visakhapatnam,
Andhra Pradesh



VSP,
15-2-2022

Sir,

Sub: Change of name of the school in the Annual Periodical Renewal Fire Certificate request regd.

Ref 1: File No. 13372/VSP/DFO/2020, Date:06/08/2020, DFO Office Visakhapatnam.

Occupancy **NOC** RC Number: 8753/VSP/DFO/2019

Ref 2: Letter No.ESE01/100/2021-PS School Education (PS) Department, Government of Andhra Pradesh Dated: 09/04/2021, NOC, to swift over to CBSC Board.

With reference to the first above, The District fire officer was please to issue Annual Periodical Renewal Fire Certificate for a period of 5 years that is from 23/07/2022- 22/07/2025.


It is brought to the notice of the DFO, Visakhapatnam that the state government issued NOC with reference to the second above, the school name was mentioned "Harbor EM High School, Vellanki, Boddapalem, Anandapuram, Visakhapatnam District".

The Secretary of CBSE, Delhi took objection that the school name should be mentioned on the Periodical Renewal Fire Certificate as on the NOC issued by the government of Andhra Pradesh as "Harbor EM High School, Vellanki, Boddapalem, Anandapuram, Visakhapatnam District".

It is therefore requested to the District Fire officer, Visakhapatnam, to change the school name on the Fire Renewal Certificate as requested in the above paragraph, at the earliest.

Thanking you,


Yours faithfully,



Y. Sanyasi Naidu

Secretary and Correspondent

Sangamitra Educational Society

SANGAMITRA EDUCATIONAL SOCIETY


Secretary & Correspondent


HEAD MASTER
HARBOR E.M. SCHOOL
VELLANKI, BODDAPALEM (V)
Anandapuram (Md), VSP Dt